

Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT	Finishes	Temperature Ratings
					(in.)		°F (°C)
PS001	5.6	Upright	SR	Norbulb	1/2	Brass, Chrome,	135, 155, 175, 200 (57,
				N5 5mm		Polyester	68, 79, 93)
PS002	5.6	Pendent	SR	Norbulb	1/2	Brass, Chrome,	135, 155, 175, 200 (57,
				N5 5mm		Polyester	68, 79, 93)
PS003	5.6	Concealed	SR	Norbulb	1/2	Brass	155, 175, 200 (68, 79,
		Pendent		N5 5mm			93)

Prepared for: Protector Safety Ind. Co., No. 3, Alley 16, Lane 228, Nan-Kang

Road Sec 2, Lu Jwu Shiang, Tao-Yuan Hsien, Taiwan (R.O.C.)

Manufacturing Location: Protector Safety Ind. Co., No. 3, Alley 16, Lane 228, Nan-Kang

Road Sec 2, Lu Jwu Shiang, Tao-Yuan Hsien, Taiwan (R.O.C.)

FM Approvals Class: 2016, 2017, 2015

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046914 Approval Granted: October 9, 2014

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne

Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT	Finishes	Temperature Ratings
					(in.)		°F (°C)
PS004	5.6	Pendent	QR	Norbulb	1/2	Brass, Chrome,	155, 175, 200 (68, 79,
				N3 3mm		Polyester	93)
PS005	5.6	Upright	QR	Norbulb	1/2	Brass, Chrome,	155, 175, 200 (68, 79,
				N3 3mm		Polyester	93)
PS006	5.6	Concealed	SR	Norbulb	1/2	Brass	155, 175, 200 (68, 79,
		Pendent		N3 3mm			93)

Prepared for: Protector Safety Ind. Co., No. 3, Alley 16, Lane 228, Nan-Kang

Road Sec 2, Lu Jwu Shiang, Tao-Yuan Hsien, Taiwan (R.O.C.)

Manufacturing Location: Protector Safety Ind. Co., No. 3, Alley 16, Lane 228, Nan-Kang

Road Sec 2, Lu Jwu Shiang, Tao-Yuan Hsien, Taiwan (R.O.C.)

FM Approvals Class: 2016, 2017, 2015

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046914 Approval Granted: October 9, 2014

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne

Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
PS007	5.6	Horizontal	SR	Norbulb	1/2	Brass, Chrome,	135, 155, 175, 200 (57,
15007	3.0	Sidewall	SIC	N5 5mm	1/2	Polyester Polyester	68, 79, 93)
PS008	5.6	Horizontal	QR	Norbulb	1/2	Brass, Chrome,	155, 175, 200 (68, 79,
		Sidewall		N3 3mm		Polyester	93)

Prepared for: Protector Safety Ind. Co., No. 3, Alley 16, Lane 228, Nan-Kang

Road Sec 2, Lu Jwu Shiang, Tao-Yuan Hsien, Taiwan (R.O.C.)

Manufacturing Location: Protector Safety Ind. Co., No. 3, Alley 16, Lane 228, Nan-Kang

Road Sec 2, Lu Jwu Shiang, Tao-Yuan Hsien, Taiwan (R.O.C.)

FM Approvals Class: 2012

FM Approval Standard: Class Series 2000 (March 2006)

Approval Identification: 3046914 Approval Granted: October 9, 2014

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

FM Approvals°

Member of the FM Global Group

Richard B. Dunne

Manager – Fire Protection

FM Approvals

1151 Boston-Providence Turnpike

Norwood, MA 02062

USA